October 2, 2009 Deluge Trim 543d




TECHNICAL DATA

PILOT REGULATING FLOW CONTROL TRIM

3" (DN80) MODEL H FLOW CONTROL VALVE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com



Valve Size	Galvanized Trim Part No.	Brass Trim Part No.
3" (DN80)	14765-1	14765-2
This trim is for use with the following Release Module Trim Kits		
I		
Release Type	Galvanized	Brass
Release Type Electric	Galvanized 10830	Brass 10832


Note: When viewing this data page online, blue text represents hyper links and will open the appropriate data page when clicked.

from those shown on this Trim Chart.

Notes: For use with Trim Charts on Page 543 e

General Notes:

- Valve must be trimmed as shown. Any deviation from trim size or arrangement may affect the proper operation of the valve.
- · Dimensions in parenthesis are millimeters.
- Viking uses ANSI tee designations (large outlet on run, small outlet on run, side outlet) in all trim call-outs.



- Note 1: Release System connection.
- **Note 2:** Alarm Connections: Connect alarm line piping to 3/4" (20 mm) NPT outlet. When using a Water Motor Alarm, a strainer is required. 1/2" (15 mm) NPT outlet is for electric Alarm Pressure Switch.
- **Note 3:** Optional non-interruptible connection for Alarm Pressure Switch to activate electric alarm panel. Note: After the Deluge Valve trips, this location cannot be shut off. Alarms may operate until the outlet chamber of the deluge valve is de-pressurized below the set point of the Alarm Pressure Switch.
- Note 4: Viking Drain Check Valve is manufactured with a 0.067" (1.7 mm) orifice to allow alarm line to drain. Do not substitute. Check label for proper orientation.




TECHNICAL DATA

PILOT REGULATING FLOW CONTROL TRIM

3" (DN80) MODEL H FLOW CONTROL VALVE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com



October 2, 2009 Deluge Trim 543f




TECHNICAL DATA

PILOT REGULATING FLOW CONTROL TRIM

3" (DN80) MODEL H FLOW CONTROL VALVE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com



THIS PAGE INTENTIONALLY LEFT BLANK