



Certificate of Compliance

This certificate is issued for the following:

Model J-1 Alarm Check Valves

Sizes: 3, 4, 6, and 8 inch NPS

(See table below)

Prepared for:

The Viking Corporation
210 N Industrial Park Dr
Hastings, MI 49058
United States

Manufactured at:

The Viking Corporation
210 N Industrial Park Dr
Hastings, MI 49058
United States

FM Approvals Class: 1041

Approval Identification: 0003042799

Approval Granted: September 15, 2011

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne', is written over a horizontal line.

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group



Certificate of Compliance

Product Designation	Description	Nominal Pipe Size, in. (mm)	Maximum Working Pressure, psi (kPa)	Remarks
Model J-1	Alarm Check Valve, Flanged Ends	3, 4, 6, 8 (80, 100, 150, 200)	300 (2070)	a, b
Model J-1	Alarm Check Valve, Grooved Ends	3, 4, 6, 8 (80, 100, 150, 200)	300 (2070)	a, b
Model J-1	Alarm Check Valve, Flange x Grooved	3, 4, 6, 8 (80, 100, 150, 200)	300 (2070)	a, b

Notes:

- a. Resilient Seat
- b. Approved for use with Model C-1 retard chamber.



Member of the FM Global Group