

# CLEAN AGENT FIRE EXTINGUISHING SYSTEM

## Warning Signs

**Minimax Fire Products** Technical Services: (480) 553-5670 Email: mxtechsupport@minimaxfp.com

The technical data described herein is for components of the Minimax Fire Products MX 1230 and MX 200 Clean Agent Systems. For design, installation, and operation instructions, refer to the latest edition of the original source documents: For MX 1230 - Installation and Service Manual (Part No. 889327), Design Manual (Part No. 889334), and Operation Manual (Part No. 889325). Or, for MX 200 - Installation and Service Manual (Part No. 889331), Design Manual (Part No. 889336), and Operation Manual (Part No. 889329).

### 1. DESCRIPTION

Minimax Fire Products MX 1230 and MX 200 Fire Extinguishing Systems require warning signs to be attached to all access doors to identify the protected enclosure, warning of the existence of a MX 1230 or MX 200 Fire Extinguishing System and the risks involved. Two types of signs are required (refer to Figures 1 and 2):

- Outside Warning Sign
- Inside Warning Sign

### 2. LISTINGS AND APPROVALS

- **UL Listed:** Clean Agent Extinguishing System Unit
- **FM Approved:** Clean Agent Fire Extinguishing System

### 3. TECHNICAL DATA

#### Specifications

- Warning Sign Types: Refer to Figure 1 below.
- Dimensions: 10" (254 mm) W x 10" (254 mm) H


#### Material Standards

- Aluminum Plate

#### Ordering Information

- To order Warning Signs for the MX 1230 Fire Extinguishing System: Refer to part number 16988 (16988-S Spanish) for the Outside Warning Sign and part number 16989 (16989-S Spanish) for the Inside Warning Sign.
- To order Warning Signs for the MX 200 Fire Extinguishing System: Refer to part number 17494 (17494-S Spanish) for the Outside Warning Sign and part number 17493 (17493-S Spanish) for the Inside Warning Sign.

Minimax Technical Data may be found on  
**Minimax Fire Products' Web site at**  
<http://www.minimaxfp.com/>.  
 The Web site may include a more recent  
 edition of this Technical Data Page.





# CLEAN AGENT FIRE EXTINGUISHING SYSTEM

## Warning Signs

Minimax Fire Products Technical Services: (480) 553-5670 Email: mxtechsupport@minimaxfp.com

