

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Ronny A. Livian, P.E., Acting Commissioner

**MEA 89-92-E Vol. XXII  
Report of Material and Equipment Acceptance Division**

**Manufacturer – The Viking Corporation**

**Trade Name(s) – The Viking Corporation.**

**Product – Systems for fire protection service.**

**Pertinent Code Section(s) – Reference Standard RS 17, NFPA 13.**

**Tests – UL 260, UL 1486, FM Class 1021.**

**Laboratory -Underwriters Laboratories, Inc., Factory Mutual Research.**

**Test Report(s) – UL File EX1193, Project 97NK31628 dated February 25, 1998; UL file EX776, Project 92NK7690, Project 93NK21586, 94NK29250, 95NK15148, 95NK27640 & 95NK10979, issued July 2, 1992 and revised June 9, 1997. FM files J.I.1B3A6.AH dated July 2, 1997, J.I.2X3A5.AH dated January 10, 1995, J.I.2X0A2.AH dated January 9, 1995.**

**Description – Dry pipe valve with quick opening device for fire protection service.**

<b>Model No.</b>	<b>Description</b>	<b>Pressure Rating</b>
<b>Dry Pipe System</b>	<b>3" (80mm), 4" (100mm), &amp; 6" (150mm) Model F-1 Dry Pipe Valve used with Quick Opening Device Model D-2 Accelerator or Model E-1 Accelerator used with Model B-1 Anti-Flood Device.</b>	<b>175 psi</b>

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated March 26, 2002, F.P. Index #0203060.

**Recommendation – That the above units be accepted on condition that all uses, locations and installations shall comply with all applicable New York City Building Codes, rules, regulations and testing requirements, and in particular with the requirements of Subchapter 17, and RS 17-2 of the Administrative Code and on further condition that:**

- 1. Underwriters Laboratories Inc.'s listing requirements and limitations shall be adhered to.**
- 2. Manufacturer's installation, maintenance procedures and limitations shall be complied with.**

**All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.**

**Final Acceptance** April 5, 2002

**Examined By** Mark Jachniewig