



# Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK130	5.6	Upright	SR	Norbulb N5 5mm, Job G5 5mm	1/2	Stainless Steel Alloy 316L (UNS-NO8367)	135, 155, 175, 200, 286, 360, 500 (57, 68, 79, 93, 141, 182, 260)
VK132	5.6	Pendent	SR	Norbulb N5 5mm, Job G5 5mm	1/2	Stainless Steel Alloy 316L (UNS-NO8367)	135, 155, 175, 200, 286, 360, 500 (57, 68, 79, 93, 141, 182, 260)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive,  
Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive,  
Hastings, MI 49058, USA

FM Approvals Class: 2016, 2017, 2042  
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3039275

Approval Granted: April 2, 2012

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

*For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.*

A handwritten signature in black ink, appearing to read "Richard B. Dunne".

Richard B. Dunne  
Group Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



*Member of the FM Global Group*