



Member of the FM Global Group

Not to be distributed outside of FM Approvals and its affiliates except by Customer

# APPROVAL REPORT

**MODEL VK592 FUSIBLE TYPE CONTROL-MODE  
(SPECIFIC APPLICATION) PENDENT STANDARD  
RESPONSE AUTOMATIC SPRINKLERS WITH A  
NOMINAL DISCHARGE COEFFICIENT OF 19.6  
GAL/MIN/(PSI)<sup>1/2</sup> IN NOMINAL TEMPERATURE  
RATINGS OF 160 AND 205°F (71 AND 96°C)**

**Prepared for:**


**The Viking Corporation  
210 North Industrial Park Road  
Hastings, MI 49058**

**Project ID: 3027482**

**Class: 2036**

**Date of Approval: 1 October 2008**

**Authorized by:**

  
Richard B. Dunne, Manager-Hydraulics Group

FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102  
Norwood, MA 02062