



Certificate of Compliance

Automatic Control Mode Sprinklers for Fire Protection

This certificate is issued for the following equipment:

Model	K	Type	Resp	Element	NPT (in.)	Finishes	Temp. Ratings °F (°C)
VK510	25.2	Pendent ESFR	FR	Fusible	1	Brass	165°, 205°F (74°, 96°C)

Manufactured by:

The Viking Corporation

Manufacturing Locations:

11305 James Street, Holland, MI 49424

210 N Industrial Park Dr. Hastings, Michigan 49058

FM Approvals confirms that the items have been found to comply with the following standard:


FM Approvals Standard 2008 (October 2006)

Project Identifier:

3035452

Date of Approval:

July 31, 2009


Richard B. Dunne
Group Manager - Hydraulics

August 4, 2009
Date



Member of the FM Global Group



Member of the FM Global Group

NOT to be distributed outside of FMGlobal except by CUSTOMER.

APPROVAL REPORT

**MODEL VK510 FUSIBLE TYPE SUPPRESSION MODE
(ESFR) PENDENT AUTOMATIC SPRINKLER WITH A
NOMINAL DISCHARGE COEFFICIENT OF 25.2
GAL/MIN/(PSI)^{1/2} IN NOMINAL TEMPERATURE
RATINGS OF 165 AND 205°F (74 AND 96°C) WITH
MODIFICATION**

Prepared for:


**The Viking Corporation
210 North Industrial Park Road
Hastings, MI 49058**

Project ID: 3025743

Class: 2026

Date of Approval: 6 July 2006

Authorized by:


Richard B. Dunne, Manager-Hydraulics Group

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102
Norwood, MA 02062



NOT to be distributed outside of FMGlobal except by CUSTOMER.

APPROVAL REPORT

**MODEL VK510 FUSIBLE TYPE
SUPPRESSION MODE (ESFR) PENDENT
AUTOMATIC SPRINKLERS WITH A NOMINAL
DISCHARGE COEFFICIENT OF 25.2 GAL/MIN/(PSI)^{1/2}
IN NOMINAL TEMPERATURE RATINGS OF 165 AND
205°F (74 AND 96°C)**

Prepared for:

**The Viking Corporation
210 North Industrial Park Road
Hastings, MI 49058**

Project ID: 3009831

Class: 2026

Date of Approval: 17 March 2003

Authorized by:


Roger L. Allard, Group Manager - Hydraulics

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102
Norwood, MA 02062

An  Global Enterprise



Certificate of Compliance

Automatic Control Mode Sprinklers for Fire Protection

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK510	25.2	ESFR Pendent	FR	Fusible	1	Brass	165°, 205°F (74°, 96°C)


Manufactured by: The Viking Corp, 210 N Industrial Park Rd, Hastings, Michigan 49058


Manufacturing Location: The Viking Corp, 210 N Industrial Park Rd, Hastings, Michigan 49058 and
The Viking Corp, 11305 James St, Holland, MI 49424

FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard 2008 (October 2006)

Project Identifier: 3026351 Date of Approval: May 5, 2009


Richard B. Dunne
Group Manager - Hydraulics


Date



Member of the FM Global Group