

CERTIFICATE OF COMPLIANCE

Certificate Number 20130829-EX5085
Report Reference EX5085-20080602
Issue Date 2013-AUGUST-29

Issued to: VIKING CORP
210 N INDUSTRIAL PARK RD
HASTINGS MI 49058


This is to certify that representative samples of SPRINKLERS, EARLY SUPPRESSION FAST RESPONSE
See Addendum Page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: NFPA 13, the National Fire Protection Association's Standard for the Installation of Sprinkler Systems

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130829-EX5085
Report Reference EX5085-20080602
Issue Date 2013-AUGUST-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Viking SIN VK502 dry pendent style, K14 ESFR sprinkler rated 165°F, maximum pressure 175 psig, with a minimum length of 8 in. and a 36-in. maximum length for maximum ceiling heights of 35 ft and maximum commodity height of 30 ft.

Viking SIN VK504 dry pendent style, K16.8 ESFR sprinkler rated 165°F, maximum pressure 175 psig, with a length of 36-in. maximum length for maximum ceiling heights of 40 ft and maximum commodity height of 35 ft.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

