

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160229-EX3836  
**Report Reference** EX3836-20060803  
**Issue Date** 2016-FEBRUARY-29

**Issued to:** VIKING CORP  
210 INDUSTRIAL PARK DR  
HASTINGS MI 49058-9706

**This is to certify that  
representative samples of**

RESIDENTIAL AUTOMATIC SPRINKLERS ;  
RESIDENTIAL AUTOMATIC SPRINKLERS CERTIFIED  
FOR EUROPE

“See Addendum Page”

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** Residential Sprinklers for Fire Protection Service UL1626  
Residential Sprinklers for Fire Protection Service ULC/ORD  
C1626

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160229-EX3836  
**Report Reference** EX3836-20060803  
**Issue Date** 2016-FEBRUARY-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## PRODUCT COVERED:

VK457 and VK4570, concealed pendent style sprinkler, discharge coefficient "K" = 4.9, fusible link heat responsive element, 165 and 205°F temperature rated residential type sprinklers with a 135°F concealed coverplate assembly.

VK474 and VK4740, concealed pendent style sprinkler, discharge coefficient "K" = 5.8, fusible link heat responsive element, 165 and 205°F temperature rated residential type sprinklers with a 135 and 165°F concealed coverplate assembly.

VK488, concealed pendent style sprinkler, discharge coefficient "K" = 3.0, fusible link heat responsive element, 165 and 205°F temperature rated residential type sprinklers with a 135 and 165°F concealed coverplate assembly.

VK4880, (Lead Free) concealed pendent style sprinkler, discharge coefficient "K" = 3.0, fusible link heat responsive element, 165 and 205°F temperature rated residential type sprinklers with a 135 and 165°F concealed coverplate assembly.

- # - Utilizes a 135°F cover plate.
- + - Utilizes a 165°F cover plate.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

