FIG. SE-5 Groove x Thread Reducing 90° Elbow

SPF/ANVIL

- SE-5 ductile iron fittings are grooved on the large end and reduced size female NPT threaded on the small end. The SE-5 fittings are ideal for all types of applications where transition from grooved to female thread is required.
- SE-5 fittings allow for convenient connection of drains, vents, pressure gauges as well as direct connection of an end of line sprinkler head.
- All sizes are UL, ULC listed and FM approved for 300 PSI working pressure.



c UL us LISTED FM APPROVED

For Listings/Approval Details and Limitations, visit our website at www.anvilintl.com or contact an Anvil® Sales Representative.

SE-5 ELBOW

Nominal Size	O.D.	Max. Wk. Pressure	X	Y	Approx. Wt. Ea.
In./DN(mm)	*In./mm*	*PSI/bar*	*In./mm*	*In./mm*	*Lbs./Kg*
1¼ x ½ *32 x 15*	1.660 *42.2*	300 *20.7*	1¾ *44*	1⅜ *35*	0.5 *0.3*
1¼ x ¾ *32 x 20*	1.660 *42.2*	300 *20.7*	1⅞ *48*	1⅜ *35*	0.5 *0.3*
1¼ x 1 *32 x 25*	1.660 *42.2*	300 *20.7*	2 *51*	1½ *38*	0.6 *0.3*
1½ x ½ *40 x 15*	1.900 *48.3*	300 *20.7*	1¾ *44*	1⅜ *35*	0.6 *0.3*
1½ x ¾ *40 x 20*	1.900 *48.3*	300 *20.7*	1⅞ *48*	1⅜ *35*	0.7 *0.3*
1½ x 1 *40 x 25*	1.900 *48.3*	300 *20.7*	2 *51*	1½ *38*	0.8 *0.4*
2 x ½ *50 x 15*	2.375 *60.3*	300 *20.7*	1¾ *44*	1⅝ *41*	0.8 *0.4*
2 x ¾ *50 x 20*	2.375 *60.3*	300 *20.7*	1⅞ *48*	1⅝ *41*	0.9 *0.4*
2 x 1 *50 x 25*	2.375 *60.3*	300 *20.7*	2 *51*	1¾ *44*	1.0 *0.5*
2½ x ½ *65 x 15*	2.875 *73.0*	300 *20.7*	1¾ *44*	1 13/16 *46*	1.2 *0.5*
2½ x ¾ *65 x 20*	2.875 *73.0*	300 *20.7*	1⅞ *48*	1 13/16 *46*	1.3 *0.6*
2½ x 1 *65 x 25*	2.875 *73.0*	300 *20.7*	2 *51*	1 15/16 *49*	1.5 *0.7*
3 x ¾ *80 x 20*	3.500 *88.9*	300 *20.7*	2 1/16 *52*	2⅜ *60*	2.2 *1.0*
3 x 1 *80 x 25*	3.500 *88.9*	300 *20.7*	2 1/16 *52*	2½ *64*	2.5 *1.1*

MATERIAL SPECIFICATIONS

CAST FITTINGS:

Ductile Iron conforming to ASTM A-536, Grade 65-45-12

COATINGS:

☐ Rust inhibiting paint Color: BLACK
☐ Other available options: Example: RAL3000 or RAL9000 Series

PROJECT INFORMATION	APPROVAL STAMP
Project:	☐ **Approved**
Address:	☐ **Approved as noted**
Contractor:	☐ **Not approved**
Engineer:	**Remarks:**
Submittal Date:	
Notes 1:	
Notes 2:	