

APPROVED SPRINKLERS FOR USE WITH FOAM CONCENTRATES

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

1. DESCRIPTION

Viking Pendent and Upright Foam-Water Sprinklers are non-aspirated foam discharge devices. Viking Pendent and Upright Foam-Water Sprinklers are FM Approved and UL Listed in both closed sprinkler (with bulb or fusible element) and open sprinkler (bulb removed) configurations.

Features:

- Tested and Approved as foam-water sprinklers with specific foam concentrates (see Performance Data).
- K-factors available: K5.6 (K80.6), K8.0 (K115.2), and K11.2 (K161.3)

2. LISTINGS AND APPROVALS

Viking Foam Water Sprinklers are FM Approved and/or UL Listed as part of a fire extinguishing system combining designated foam concentrates, bladder tanks and proportioning devices. Approved and Listed system components can be found at **www.approvalguide.com** and **https://ig.ulprospector.com**.



FM Approved – Low-Expansion Foam Systems (FM5130)

UL Listed – GFGV.EX27255 (UL162)

"SFFF compatible" refers to this product as being part of a SFFF Foam system that has been tested to recognized standards. Not all configurations are available. Please consult technical data and/or the Approval/Listing for usage requirements.

Refer to the FM Approval and UL Listings tables in this document for technical performance data.

3. TECHNICAL DATA

Refer to the applicable sprinkler's data page for product data.

4. SCOPE OF DELIVERY

Ensure that all components are complete and in good condition. Viking Foam/ Water Sprinklers are supplied boxed with protective shield or cap.

5. AVAILABILITY

Please contact Viking for further information.

Americas:

The Viking Corporation 5150 Beltway SE Caledonia, MI 49316 Tel.: (800) 968–9501 Fax: 269–818–1680 Technical Services: 1–877–384–5464 techsvcs@vikingcorp.com

6. PRODUCT VARIANTS

Please refer to relevant sprinkler data page.

7. SCOPE OF DELIVERY

Ensure that all components are complete and in good condition. Viking Foam/Water Sprinklers are supplied boxed with protective shield or cap.

8. INSTALLATION

Refer to appropriate Installation Standards (i.e. NFPA, VdS, LPCB, etc.) and / or applicable FM Global Property Loss Prevention Data Sheets such as 4-12, Foam Extinguishing Systems.



WARNING: Cancer and Reproductive Harm- www.P65Warnings.ca.gov	
--	--





APPROVED SPRINKLERS FOR USE WITH FOAM CONCENTRATES

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

9. OPERATION

During fire conditions, the heat-sensitive liquid in the glass bulb expands, causing the glass to shatter, releasing the pip cap and sealing spring assembly. Water or Foam/Water Solution flowing through the sprinkler orifice strikes the sprinkler deflector, forming a uniform spray pattern to extinguish or control the fire.

10. GUARANTEE

For details of warranty, refer to Viking's current list price schedule or contact Viking directly.

11. INSPECTION, TESTS AND MAINTENANCE

Refer to respective requirements, according to the relevant standards for Inspection, Testing and Maintenance. Refer to NFPA 25 for Inspection, Testing and Maintenance requirements.

If applicable, refer to FM Global Property Loss Prevention Datasheet 4-12 for specific test and commissioning criteria. In addition, the "Authority Having Jurisdiction" (AHJ) may have additional maintenance, testing and inspection requirements that must be followed.

WARNING

Any system maintenance or testing that involves placing a control valve or detection system out of service may eliminate the fire protection capabilities of that system. Prior to proceeding, notify all Authorities Having Jurisdiction. Consideration should be given to employment of a fire patrol in the affected areas.

12. DISPOSAL



At end of use the product described here should be disposed of via the national recycling system.

13. ACCESSORIES AND SPARE PARTS

Please refer to relevant sprinkler data page.



APPROVED SPRINKLERS FOR USE WITH FOAM CONCENTRATES

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

	FM APPROVALS: HYDROCARBONS ¹													
_	Nominal K-factor			nkler ication		Hei	ight			² Foam	Water D	ischarge		sted ³ nkler
Foam Concentrate				er (SIN)	Mini	mum	Maxi	mum	Design	Density	Der	sity		ssure
	U.S.	Metric ^₄	Upright	Pendent	Ft.	m	Ft.	m	gpm/ft ²	Lpm/m ²	gpm/ft ²	Lpm/m ²	PSI	bar
	5.6	80.6	VK1001 VK3001		6	1.8	24.8	7.6	0.3	12.2	0.3	12.2	29	1.99
	5.6	80.6		VK1021 VK3021	6	1.8	20	6.1	0.3	12.2	0.3	12.2	29	1.99
Fomtec Enviro ARK	8.0	115.2	VK200 VK204 VK350 VK351		9	2,7	45	13,7	0.4	16,3	0.4	16,3	25	1,72
	8.0	115.2		VK2021 VK2022 VK3521 VK3522	8.5	2,6	44	13,4	0.3	12,2	0.3	12,2	14	0,97
	11.2	161.3	VK530 VK531		9	2,7	45	14	0.4	16,3	0.4	16,3	13	0,89
	11.2	161.3		VK377 VK536	6	1.8	25.2	8	0.4	16.3	0.4	16.3	13	0.89
	5.6	80.6	VK1001 VK3001		6	1.8	24.8	7.6	0.2	8.1	0.3	12.2	13	0.89
	5.6	80.6		VK1021 VK3021	6	1.8	44	13.4	0.2	8.1	0.3	12.2	13	0.89
Fomtec Enviro USP	8.0	115.2	VK200 VK204 VK350 VK351		9	2.7	45	13.7	0.3	12.2	0.3	12.2	14	0.96
	8.0	115.2		VK2021 VK3521 VK3522 VK2022	8	2.4	44	13.4	0.3	12.2	0.3	12.2	14	0.96
	11.2	161.3		VK377 VK536	6	1.8	25.2	8	0.3	12.2	0.3	12.2	7	0.48

TABLE 1

1. This table shows approvals available at the time of printing.

2. Density indicated is minimum application density required per FM5130 Standard for Foam Extinguishing Systems. This density cannot be reduced.

3. The pressure indicated is the minimum starting pressure required for the sprinkler. However, the minimum density shown overrides the minimum starting pressure (depending on head spacing) and cannot be reduced.

4. Metric K-factor shown is for use when pressure is measured in bar. When pressure is measured in kPa, divide the metric K-factor shown by 10.0.



APPROVED SPRINKLERS FOR USE WITH FOAM CONCENTRATES

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

TABLE 2

	FM APPROVALS: JET A1 ¹													
	Nominal K-factor			nkler		Hei	ght		Listed	² Foam	Water D	ischarge		ted ³
Foam Concentrate				ication er (SIN)	Mini	mum	Maxi	mum	Design	Density		sity		nkler ssure
	U.S.	Metric ^₄	Upright	Pendent	Ft.	m	Ft.	m	gpm/ft ²	Lpm/m ²	gpm/ft ²	Lpm/m ²	PSI	bar
Fomtec Enviro USP	5.6	80.6		VK1021, VK3021	8.5	2.6	44	13.4	0.2	8.1	0.3	12.2	13	0.89

1. This table shows approvals available at the time of printing.

2. Density indicated is minimum application density required per FM5130 Standard for Foam Extinguishing Systems. This density cannot be reduced.

3. The pressure indicated is the minimum starting pressure required for the sprinkler. However, the minimum density shown overrides the minimum starting pressure (depending on head spacing) and cannot be reduced.

4. Metric K-factor shown is for use when pressure is measured in bar. When pressure is measured in kPa, divide the metric K-factor shown by 10.0.

	FM APPROVALS: ALCOHOL - IPA ¹													
	Nominal			nkler ication		Hei	ght		Listed ² Foam		Tested ³ Sprinkler			
Foam Concentrate	K-fa	actor		er (SIN)	Mini	mum	Maxi	mum	Design Density			sure		
	U.S.	Metric ^₄	Upright	Pendent	Ft.	m	Ft.	m	gpm/ft ²	Lpm/m ²	PSI	bar		
	5.6	80.6	VK1001 VK3001		6	1.8	24.8	7.6	0.3	12.2	29	1.99		
	5.6	80.6		VK1021 VK3021	6	1.8	24	7.3	0.3	12.2	29	1.99		
Fomtec	8.0	115.2	VK200 VK204 VK350 VK351		6.5	2	45	13.7	0.4	16.3	25	1.7		
Enviro ARK	8.0	115.2		VK2021 VK2022 VK3521 VK3522	6	1.8	44	13.4	0.3	12.2	14	0.97		
	11.2	161.3		VK377 VK536	6	1.8	44	13.4	0.4	16.3	13	0.89		
	11.2	161.3	VK530 VK531		6	1.8	45	13.7	0.4	16.3	13	0.89		

TABLE 3

1. This table shows approvals available at the time of printing.

2. Density indicated is minimum application density required per FM5130 Standard for Foam Extinguishing Systems. This density cannot be reduced.

3. The pressure indicated is the minimum starting pressure required for the sprinkler. However, the minimum density shown overrides the minimum starting pressure (depending on head spacing) and cannot be reduced.

4. Metric K-factor shown is for use when pressure is measured in bar. When pressure is measured in kPa, divide the metric K-factor shown by 10.0.



APPROVED SPRINKLERS FOR USE WITH FOAM CONCENTRATES

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

TABLE 4

FM APPROVALS: KETONE - ACETONE ¹													
	Nominal		Sprinkler Identification			Hei	ght		Listed ² Foam		Tested ³ Sprinkler		
Foam Concentrate	K-fa	actor		er (SIN)	Mini	mum	Maxi	mum	Design	Density		ssure	
	U.S.	Metric ^₄	Upright	Pendent	Ft.	m	Ft.	m	gpm/ft ²	Lpm/m ²	PSI	bar	
	5.6	80.6	VK1001 VK3001		6	1.8	24.8	7.6	0.3	12.2	29	1.99	
	5.6	80.6		VK1021 VK3021	6	1.8	24	7.3	0.3	12.2	29	1.99	
Fomtec	8.0	115.2	VK200 VK204 VK350 VK351		6.5	2	45	13.7	0.3	12.2	14	0.97	
Enviro ARK	8.0	115.2	-	VK2021 VK2022 VK3521 VK3522	6	1.8	44	13.4	0.3	12.2	14	0.97	
	11.2	161.3	VK530 VK531		6	1.8	45	13.7	0.3	12.2	7	0.48	
	11.2	161.3		VK377 VK536	6	1.8	25.2	8	0.3	12.2	7	0.48	

1. This table shows approvals available at the time of printing.

2. Density indicated is minimum application density required per FM5130 Standard for Foam Extinguishing Systems. This density cannot be reduced.

3. The pressure indicated is the minimum starting pressure required for the sprinkler. However, the minimum density shown overrides the minimum starting pressure (depending on head spacing) and cannot be reduced.

4. Metric K-factor shown is for use when pressure is measured in bar. When pressure is measured in kPa, divide the metric K-factor shown by 10.0.

FM APPROVALS: ETHANOL ¹													
	Nominal		Sprinkler Identification			Height				Listed ² Foam		sted ³ nkler	
Foam Concentrate	K-fa	ictor		er (SIN)	Mini	mum	Maxi	mum	Design	Density		ssure	
	U.S.	Metric ⁴	Upright	Pendent	Ft.	m	Ft.	m	gpm/ft ²	Lpm/m ²	PSI	bar	
Fomtec Enviro ARK	8.0	115.2	VK200 VK204 VK350 VK351		6.5	2	45	13,7	0.3	12.2	14	0.97	
	8.0	115.2		VK2021 VK2022 VK3521 VK3522	6.0	1.8	44.8	13.7	0.30	12.2	14	0.97	
	11.2	161.3	VK530 VK531		7.7	2.3	20.6	6.3	0.30	12.2	7	0.48	
	11.2	161.3		VK377 VK536	6.0	1.8	44.8	13.7	0.30	12.2	7	0.48	

TABLE 5

1. This table shows approvals available at the time of printing.

2. Density indicated is minimum application density required per FM5130 Standard for Foam Extinguishing Systems. This density cannot be reduced.

3. The pressure indicated is the minimum starting pressure required for the sprinkler. However, the minimum density shown overrides the minimum starting pressure (depending on head spacing) and cannot be reduced.

4. Metric K-factor shown is for use when pressure is measured in bar. When pressure is measured in kPa, divide the metric K-factor shown by 10.0.



APPROVED SPRINKLERS FOR USE WITH FOAM CONCENTRATES

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058

Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

TABLE 6

UL LISTINGS: HYDROCARBON FUELS ¹												
Foam Concentrate	Nominal	K-factor	Identif	nkler ication er (SIN)		² Foam Density	Tested ³ Sprinkler Pressure					
	U.S.	Metric⁴	Upright	Pendent	gpm/ft ²	Lpm/m ²	PSI	bar				
	5.6	80.6		VK1021 VK3021	0.16	6.5	7	0.48				
	5.6	80.6	VK1001 VK3001		0.16	6.5	7	0.48				
Fomtec Enviro USP⁵	8.0	115.2		VK2021 VK2022 VK3521 VK3522	0.22	9.0	7	0.48				
	11.2	161.3	VK530 VK531 VK533	VK377 VK536	0.32	13	7	0.48				

1. This table shows approvals available at the time of printing.

2. Density indicated is minimum application density required per UL162 Standard for Foam Extinguishing Systems. This density cannot be reduced.

3. The pressure indicated is the minimum starting pressure required for the sprinkler. However, the minimum density shown overrides the minimum starting pressure (depending on head spacing) and cannot be reduced.

4. Metric K-factor shown is for use when pressure is measured in bar. When pressure is measured in kPa, divide the metric K-factor shown by 10.0.

5. For freshwater-use only.

TABLE 7

UL LISTINGS: JET A1												
Foam Concentrate	Nominal	K-factor		nkler ication er (SIN)		² Foam Density	Tested ³ Sprinkler Pressu					
	U.S.	Metric ^₄	Upright	Pendent	gpm/ft ²	Lpm/m ²	PSI	bar				
Fomtec Enviro USP⁵	5.6	80.6		VK1021 VK3021	0.16	6.5	7	0.48				

1. This table shows approvals available at the time of printing.

2. Density indicated is minimum application density required per UL162 Standard for Foam Extinguishing Systems. This density cannot be reduced.

3. The pressure indicated is the minimum starting pressure required for the sprinkler. However, the minimum density shown overrides the minimum starting pressure (depending on head spacing) and cannot be reduced.

4. Metric K-factor shown is for use when pressure is measured in bar. When pressure is measured in kPa, divide the metric K-factor shown by 10.0.

5. For freshwater-use only.