



USQTC.S309 Extinguishing System Attachments, Fire Alarm

[Page Bottom](#)

Extinguishing System Attachments, Fire Alarm

[See General Information for Extinguishing System Attachments, Fire Alarm](#)

POTTER ELECTRIC SIGNAL CO

S309

2081 CRAIG RD
PO BOX 28480
ST LOUIS, MO 63146 USA

Dry-Pipe or Wet-Pipe Sprinkler Attachments, Models WFTA, WFTPD, WFTRA, 125 V dc, 0.1 A.

Water Supply Valve Position Signals, Models OSYSU-1, OSYSU-2, Contact rating: 125/250 V ac, 15 A; 125 V dc, 0.5 A; 250 V dc, 0.25 A; Model PTS-B, Contact rating: 28 V ac-dc, 0.25 A; Model PMS, Contact rating: 24 V ac-dc, 0.15 A; 120 V dc, 0.1 A; Models PCVS-1, -2, Contact rating: 125/250 V ac, 5.0 A; 125/250 V dc, 0.25 A; 30 V dc, 2.5 A.

Wet-Pipe Sprinkler System Attachments Waterflow indicators (vane type), Models VS-SP, VSR-F, Contact rating: 125/250 V ac, 15 A; 125 V dc, 0.5 A; 250 V dc, 0.25 A; Model VSR-SF, Contact rating: 125/250 V ac, 10 A, 0-30 V dc, 2 A.

Waterflow and Pressure Supervisory, Models PS-10, WFSRC, pressure 0-138 kPa; Models PS-40, PS-100, PS-120, pressure 138-1550 kPa. Contact ratings: 125/250 V ac, 10 A; 30 V dc, 2.5 A.

[Last Updated](#) on 2004-03-04

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2008 Underwriters' Laboratories of Canada®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the Online Certifications Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories of Canada" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories of Canada®"

An independent organization working for a safer world with integrity, precision and knowledge.

