



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK178	5.6	Dry Adj. HSW	QR	Job F3-XS 3mm	1	Brass, Bright Brass, Chrome	155, 175, 200, 286 (68, 79, 96, 141)
VK180	5.6	Dry Rec. Pendent	QR	Job F3-XS 3mm	1	Brass, Chrome, Polyester	155, 175, 200 (68, 79, 96)
VK182	5.6	Dry Rec. HSW	QR	Job F3-XS 3mm	1	Brass, Bright Brass, Chrome	155, 175, 200 (68, 79, 96)

Prepared for: The Viking Corporation, 210 North Industrial Park Dr, Hastings, MI 49085
Manufacturing Location: 210 North Industrial Park Dr, Hastings, MI 49085

FM Approval Class: 2013
FM Approval Standard: Class Series 2000 (March/2006)

Project Identifier: 3035161 **Date of Approval:** June 13, 2011

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in black ink, appearing to read 'Richard B. Dunne', is written over a horizontal line.

Richard B. Dunne
Manager - Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK172	5.6	Dry Pendent	QR	3mm	1	Brass, Chrome, Polyester	155, 175, 200, 286 (68, 79, 96, 141)
VK174	5.6	Dry HSW	QR	3mm	1	Brass, Bright Brass, Chrome	155, 175, 200, 286 (68, 79, 96, 141)
VK176	5.6	Dry Adj. Pendent	QR	3mm	1	Brass, Chrome, Polyester	155, 175, 200, 286 (68, 79, 96, 141)

Prepared for: The Viking Corporation, 210 North Industrial Park Dr, Hastings, MI 49085
Manufacturing Location: 210 North Industrial Park Dr, Hastings, MI 49085

FM Approval Class: 2013
FM Approval Standard: Class Series 2000 (March/2006)

Project Identifier: 3035161 **Date of Approval:** June 13, 2011

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in blue ink, appearing to read 'Richard B. Dunne', is written over a horizontal line.

Richard B. Dunne
Manager - Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

