



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	Connection	Finishes	Temperature Ratings °F (°C)
VK502	14.0	ESFR Dry Pendent	QR	Fusible	1.5 in. NPT	Brass	165 (74)
VK502	14.0	ESFR Dry Pendent	QR	Fusible	2 in. Grooved	Brass	165 (74)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive
Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive
Hastings, MI 49058, USA

FM Approvals Class: 2008

FM Approval Standard: Class Series 2008 (October 2006) and Draft Performance Requirements for Quick-Response Standard-Coverage Dry Pendent Storage Automatic Sprinklers (also referred to as Dry Pendent Suppression Mode Sprinklers) with a Nominal Discharge Coefficient of 14.0 gal/min/(psi)^{1/2} [200 L/min/(bar)^{1/2}]

Approval Identification: 3045631

Approval Granted: October 15, 2012
Supersedes Certificate Dated June 14, 2012

Said Approval is subject to satisfactory field performance, continuing follow-up Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in black ink, appearing to read "Richard B. Dunne", is written over a white rectangular background.

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group