



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK461	2.8	Concealed Pendent	SR	3mm	1/2	Brass	155, 175, 200 (68, 79, 93)
VK462	5.6	Concealed Pendent	SR	3mm	1/2	Brass	155, 175, 200 (68, 79, 93)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive
Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive
Hastings, MI 49058, USA

FM Approvals Class: 2015
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3047685

Approval Granted: January 17, 2013

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in dark ink, appearing to read "Richard B. Dunne".

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group