



# Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK544	11.2	Dry Pendent	SR	Fusible	1-1/4	Brass, Chrome, Polyester, NICOTEF	165, 205, 280 (74, 96, 138)
VK547	11.2	Dry Pendent	QR	Fusible	1-1/4	Brass, Chrome, Polyester, NICOTEF	165, 205, 280 (74, 96, 138)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive,  
Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive,  
Hastings, MI 49058, USA

FM Approvals Class: 2013  
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3051318

Approval Granted: September 25, 2015

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



*Member of the FM Global Group*

A handwritten signature in black ink that reads "D.B. Fuller".

David B. Fuller  
AVP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



# Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK545	11.2	Dry Recessed Pendent	SR	Fusible	1-1/4	Brass, Chrome, Polyester, NICOTEF	165, 205 (74, 96)
VK548	11.2	Dry Recessed Pendent	QR	Fusible	1-1/4	Brass, Chrome, Polyester, NICOTEF	165, 205 (74, 96)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive,  
Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive,  
Hastings, MI 49058, USA

FM Approvals Class: 2013, 2015  
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3051318

Approval Granted: September 25, 2015

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller  
AVP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA



# Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK546	11.2	Dry Adjustable Pendent	SR	Fusible	1-1/4	Brass, Chrome, Polyester, NICOTEF	165, 205, 280 (74, 96, 138)
VK549	11.2	Dry Adjustable Pendent	QR	Fusible	1-1/4	Brass, Chrome, Polyester, NICOTEF	165, 205, 280 (74, 96, 138)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive,  
Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive,  
Hastings, MI 49058, USA

FM Approvals Class: 2013  
FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3051318

Approval Granted: September 25, 2015

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller  
AVP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA

