



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK325	2.8	Upright	QR	3 mm	1/2	Brass, Chrome	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
VK326	2.8	Upright	QR	Fusible	1/2	Brass, Chrome	165, 205, 280 (74, 96, 138)
VK329	2.8	Pendent	QR	3 mm	1/2	Brass, Chrome	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
VK330	2.8	Pendent	QR	Fusible	1/2	Brass, Chrome	165, 205, 280 (74, 96, 138)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

FM Approvals Class: 2002
FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: 3060481

Approval Granted: March 22, 2019

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
OVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group