

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
*VK1001	5.6	Upright	SR	5mm	1/2	Brass, Chrome, Polyester, ENT	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

^{*}Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory vacuum pressure of -3 psi (-207 mbar)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2016

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager - Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062, USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT	Finishes	Temperature
					(in.)		Ratings
							° F (° C)
*VK1021	5.6	Pendent	SR	5mm	1/2	Brass, Chrome,	135, 155, 175, 200, 286
						Polyester, ENT	(57, 68, 79, 93, 141)
*VK1021	5.6	Recessed	SR	5mm	1/2	Brass, Chrome,	135, 155, 175, 200 (57,
		Pendent				Polyester, ENT	68, 79, 93)

^{*}Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory vacuum pressure of -3 psi (-207 mbar)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2015, 2017

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Туре	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK1021	5.6	In-Rack Pendent	SR	5mm	1/2	Brass, Chrome, Polyester, ENT	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2005

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

FM Approvals[®]

Member of the FM Global Group

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA



This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT	Finishes	Temperature
					(in.)		Ratings
							° F (° C)
*VK2001	8.0	Upright	SR	5mm	3/4	Brass, Chrome,	135, 155, 175, 200, 286
						Polyester, ENT	(57, 68, 79, 93, 141)
*VK2002	8.0	Upright	SR	5mm	1/2	Brass, Chrome,	135, 155, 175, 200, 286
						Polyester, ENT	(57, 68, 79, 93, 141)

^{*}Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory vacuum pressure of -3 psi (-207 mbar)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2001

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT	Finishes	Temperature
					(in.)		Ratings
							° F (° C)
*VK2021	8.0	Pendent	SR	5mm	3/4	Brass, Chrome,	135, 155, 175, 200, 286
						Polyester, ENT	(57, 68, 79, 93, 141)
*VK2021	8.0	Recessed	SR	5mm	3/4	Brass, Chrome,	135, 155, 175, 200 (57,
		Pendent				Polyester, ENT	68, 79, 93)

^{*}Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory vacuum pressure of -3 psi (-207 mbar)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2001, 2015

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager - Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062, USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Туре	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK2021	8.0	In-Rack Pendent	SR	5mm	3/4	Brass, Chrome, Polyester, ENT	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2005

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA

FM Approvals*



This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Туре	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
*VK2022	8.0	Pendent	SR	5mm	1/2	Brass, Chrome,	135, 155, 175, 200, 286
						Polyester, ENT	(57, 68, 79, 93, 141)
*VK2022	8.0	Recessed	SR	5mm	1/2	Brass, Chrome,	135, 155, 175, 200 (57,
		Pendent				Polyester, ENT	68, 79, 93)

^{*}Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory vacuum pressure of -3 psi (-207 mbar)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2001, 2015

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Туре	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK2022	8.0	In-Rack	SR	5mm	1/2	Brass, Chrome,	135, 155, 175, 200, 286
		Pendent				Polyester, ENT	(57, 68, 79, 93, 141)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2005

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to $\underline{www.approvalguide.com}$

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
*VK3001	5.6	Upright	QR	3mm	1/2	Brass, Chrome, Polyester, ENT	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

^{*}Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory vacuum pressure of -3 psi (-207 mbar)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2016

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager - Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062, USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Туре	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
*VK3021	5.6	Pendent	QR	3mm	1/2	Brass, Chrome,	135, 155, 175, 200, 286
						Polyester, ENT	(57, 68, 79, 93, 141)
*VK3021	5.6	Recessed	QR	3mm	1/2	Brass, Chrome,	135, 155, 175, 200 (57,
		Pendent				Polyester, ENT	68, 79, 93)

^{*}Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory vacuum pressure of -3 psi (-207 mbar)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2015, 2017

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK3021	5.6	In-Rack Pendent	QR	3mm	1/2	Brass, Chrome, Polyester, ENT	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2005

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT	Finishes	Temperature
					(in.)		Ratings
							° F (° C)
*VK3501	8.0	Upright	QR	3mm	3/4	Brass, Chrome,	135, 155, 175, 200, 286
						Polyester, ENT	(57, 68, 79, 93, 141)
*VK3502	8.0	Upright	QR	3mm	1/2	Brass, Chrome,	135, 155, 175, 200, 286
						Polyester, ENT	(57, 68, 79, 93, 141)

^{*}Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory vacuum pressure of -3 psi (-207 mbar)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2001

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

	Model	K	Type	Resp.	Element	NPT	Finishes	Temperature
						(in.)		Ratings
								° F (° C)
Ī	*VK3521	8.0	Pendent	QR	3mm	3/4	Brass, Chrome,	135, 155, 175, 200, 286
							Polyester, ENT	(57, 68, 79, 93, 141)
	*VK3521	8.0	Recessed	QR	3mm	3/4	Brass, Chrome,	135, 155, 175, 200 (57,
			Pendent				Polyester, ENT	68, 79, 93)

^{*}Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory vacuum pressure of -3 psi (-207 mbar)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2001, 2015

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Туре	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK3521	8.0	In-Rack Pendent	QR	3mm	3/4	Brass, Chrome, Polyester, ENT	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2005

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike Norwood, MA 02062, USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT	Finishes	Temperature
					(in.)		Ratings
							° F (° C)
*VK3522	8.0	Pendent	QR	3mm	1/2	Brass, Chrome,	135, 155, 175, 200, 286
						Polyester, ENT	(57, 68, 79, 93, 141)
*VK3522	8.0	Recessed	QR	3mm	1/2	Brass, Chrome,	135, 155, 175, 200 (57,
		Pendent				Polyester, ENT	68, 79, 93)

^{*}Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory vacuum pressure of -3 psi (-207 mbar)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2001, 2015

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA





This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK3522	8.0	In-Rack Pendent	QR	3mm	1/2	Brass, Chrome, Polyester, ENT	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

Manufacturing Location: The Viking Corporation, 5150 Beltway Drive SE

Caledonia, MI 49316, USA

FM Approvals Class: 2005

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR455141 Approval Granted: July 20, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062, USA

