



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK4621*	5.6	Concealed Pendent	SR	3mm	1/2	Brass	155, 175, 200 (68, 79, 93)
VK4921*	5.6	Concealed Pendent	SR	5mm	1/2	Brass	155, 175, 200 (68, 79, 93)

*Approved for use in FM Approved vacuum sprinkler systems with a maximum supervisory pressure of -3 psi (-207 mbar)

Prepared for:

The Viking Corporation, 5150 Beltway Drive SE
Caledonia, MI 49316 USA

Manufacturing Location:

The Viking Corporation, 210 North Industrial Park Drive
Hastings, MI 49058 USA

FM Approvals Class: 2015

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR457463

Approval Granted: October 15, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller

VP, Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA