



# Certificate of Compliance

This certificate is issued for the following equipment:

## Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK204	8.0	Upright	SR	Fusible	3/4	Brass, Polyester	165, 220, 286 (74, 104, 141)
VK562	8.0	In-Rack Upright	SR	Fusible	3/4	Brass	165, 220, 286 (74, 104, 141)

**Prepared for:** The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058

**Manufacturing Location:** The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058

FM Approvals Class: 2001, 2005

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3057518

Approval Granted: February 16, 2017

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, reading 'D. B. Fuller'.

David B. Fuller  
AVP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062 USA



*Member of the FM Global Group*