



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
VK377	11.2	Pendent	QR	Job 3mm-XS	3/4	Brass, NICOTEF	155, 175, 200, 286 (68, 79, 93, 141)
VK531	11.2	Upright	QR	Job 3mm-XS	3/4	Brass, Chrome, NICOTEF	155, 175, 200, 286 (68, 79, 93, 141)
VK532	11.2	EC Upright	QR	Job 3mm-XS	3/4	Brass, Chrome, Polyester, NICOTEF	155, 175, 200, 286 (68, 79, 93, 141)

Prepared for: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

Manufacturing Location: The Viking Corporation, 210 North Industrial Park Drive, Hastings, MI 49058, USA

FM Approvals Class: 2009
FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: 3062536

Approval Granted: April 29, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read "D.B. Fuller".

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA