

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190319-EX3836  
**Report Reference** EX3836-20160621  
**Issue Date** 2019-MARCH-19

**Issued to:** VIKING CORP  
210 INDUSTRIAL PARK DR  
HASTINGS MI 49058-9706

**This certificate confirms that representative samples of** RESIDENTIAL AUTOMATIC SPRINKLERS  
See Addendum Page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL1626, Standard for Residential Sprinklers for Fire-Protection Service  
ULC/ORD C-1626-03, Other Recognized Document for Residential Sprinklers for Fire-Protection Service

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190319-EX3836  
**Report Reference** EX3836-20160621  
**Issue Date** 2019-MARCH-19

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

VK494 and VK4940 concealed pendent style sprinkler, discharge coefficient "K" = 4.9. VK496 and VK4960, concealed pendent style sprinkler, discharge coefficient, "K" = 3.0, VK498 and VK4980, concealed pendent style sprinkler, discharge coefficient, "K" = 5.8, (3 mm glass bulb type) heat responsive element, residential type sprinklers as shown below. The VK494 and VK4940 sprinklers utilize a 135°F cover plate assembly and the VK498, VK4980, VK496, and VK4960 sprinklers utilize a 135 and 165°F cover plate assembly.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

